10311 Cement Plant Road
Brooksville, Florida 34601
Telephone (352) 796-7241
Fax (352) 754-9836

CEMENT MILL TEST REPORT

Cement Identified as: BROCO STUCCO MASONRY
Plant: Cemex Brooksville Cement
Location: Brooksville, FL
Production Date:

Physical Analysis	Test Results	Specifications
325 Mesh Residue	1.99 %	24% Max.
Gillmore Set:		
Initial (mins.)	138	90 Min.
Final (mins.)	238	1440 Max.
Air Content of Mortar	17 %	8% Min. 19% Max.
Autoclave Expansion	-0.01 %	1.0 % Max.
Compressive Strength		
7 Day	1,962 PSI	1800 PSI Min.
28 Day	3,061 PSI	2500 PSI Min.
Water Retention	86 %	70% Min.

WE CERTIFY THAT BROCO STUCCO MASONRY CEMENT MEETS ASTM C-91 AND C-1328 FOR TYPE S.

Cement covered by this Mill Certificate has been produced in the U.S. A.
28 day strengths are from the previous month.

Quality Control Manager